

— Emission Limitations for Existing Area Source Boiler MACT

40 CFR Part 63, Subpart JJJJJJ • Summary of Emission Limitations for New Sources

Subcategory ^(a)	Mercury (HG)	Carbon Monoxide (CO) at 3% Oxygen (O ₂)	Particulate Matter (PM)	
	lb/MMBtu ^(b)	ppm ^(c)	≥ 30 MMBtu/hr ^(b)	≥ 10 to < 30 MMBtu/hr ^(b)
Existing Small Units	-	-	-	-
Existing Large Coal (excluding limited-use boilers)	2.20E-05	420	-	-

(a) A small source has a rated heat input capacity of less than 10 MMBtu/hr. A large source has a rated heat input capacity of 10 MMBtu/hr or greater.

(b) Pound per Million British Thermal Unit (lb/MMBtu).

(c) Parts Per Million (ppm).