

— Emission Limitations for New Area Source Boiler MACT

40 CFR Part 63, Subpart JJJJJJ • Summary of Emission Limitations for New Sources

Subcategory <sup>(a)</sup>	Mercury (HG)	Carbon Monoxide (CO) at 3% Oxygen (O <sub>2</sub> )	Particulate Matter (PM)	
	lb/MMBtu <sup>(b)</sup>	ppm <sup>(c)</sup>	≥ 30 MMBtu/hr <sup>(b)</sup>	≥ 10 to < 30 MMBtu/hr <sup>(b)</sup>
New Small Units	-	-	-	
New Large Coal (excluding limited-use boilers)	2.20E-05	420	3.00E-02	4.20E-01
New Large Biomass (excluding seasonal boilers and limited-use boilers)	-	-	3.00E-02	7.00E-02
New Large Oil (excluding seasonal boilers and limited-use boilers)	-	-	3.00E-02	

(a) A small source has a rated heat input capacity of less than 10 MMBtu/hr. A large source has a rated heat input capacity of 10 MMBtu/hr or greater.

(b) Pound per Million British Thermal Unit (lb/MMBtu).

(c) Parts Per Million (ppm).